

LOCATION 1105 FAirfield Dr. CITY GAstonia

BETWEEN Clinton STREET & E. MAPle Ave. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8</u>	<u>P</u>	<u>164'</u>	<u>9-3-02</u>		
MAIN TO PROP LINE	<u>5/8</u>	<u>P</u>	<u>16'</u>			
PROP LINE TO BLDG	<u>5/8</u>	<u>P</u>	<u>154'</u>			

ENTERS _____ BRANCHED INTO _____

TAP SIZE 3/4 PRESSURE 60 PSI INCHES W C LOCATION 16' W. OF FAirfield Dr & 238' S. of Clinton Dr.

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY CR

MAIN SIZE 2 C I _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED _____

DEPTH 3 FT 6 IN LOCATION 16' W. OF FAirfield Dr

"A" P/S READING 1.4 TOTAL ANODES 1# - 17# - LR # -

REMARKS Ran New Service

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>PRiser</u>
P/S Pipeline Lead White Existing Main	<u>E</u>	

