

LOCATION 1305 Fairfield Dr. CITY Concord
BETWEEN Clinton STREET & Hawthorne STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>10'</u>	<u>7-2-94</u>	<u>Tied over 204' of</u>	
MAIN TO PROP. LINE					<u>Ext 3/4" to Ext</u>	
PROP. LINE TO BLDG.					<u>2" Plastic main</u>	

ENTERS: 1305 BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION _____


PRESSURE TEST: @ 100 psi For 14 Hrs. By ED

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 3 Ft. 6 In. LOCATION _____

"A" P/S READING 1.2 TOTAL ANODES 1# 17 # _____ L.R. # _____

REMARKS: Tracer wire tied off at main



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S Riser</u>	<u>1.2</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY