

LOCATION 1408 Fairfield Dr. CITY Gastonia
BETWEEN Hawthorne STREET & Clinton STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>45'</u>	<u>7-2-54</u>	<u>Tied own</u>	<u>94' of EXT 3/4</u>
MAIN TO PROP. LINE					<u>Plastic main</u>	<u>2"</u>
PROP. LINE TO BLDG.						

ENTERS: 1408 BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION _____

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By EP


MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1993

DEPTH: 3 Ft. 6 In. LOCATION _____

"A" P/S READING P TOTAL ANODES 1# 1 17# _____ L.R. # _____

REMARKS:

Tie own wire tied off at main



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u> <u>R. Ger.</u>	<u>1.2</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY