

LOCATION 1505 Fair Field Dr. CITY Boston
BETWEEN Hawthorne Ave. STREET & Dartmouth Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>5'</u>	<u>6-25-94</u>	<u>Tied over 61'</u>	<u>Existing 3/4</u>
MAIN TO PROP. LINE					<u>C/W</u>	
PROP. LINE TO BLDG.						

ENTERS: 1505 BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 212' W of C of Dartmouth Dr.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1993

DEPTH: 4 Ft. 0 In. LOCATION 17' S of C of Fair Field Dr.

"A" P/S READING Plastic TOTAL ANODES 1* 17* L.R. #

REMARKS: Tied Trace wire OFF AT Tee Bare Main Replacement Program



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser 1.0
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY