

LOCATION 1603 + 1601 Fair Field Dr ^{SPLIT} Service CITY GASTONIA
BETWEEN 1605 Fair Field Dr STREET & Hawthorne Ave STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>5'</u>	<u>6-25-94</u>	<u>Tied over 120'</u>	<u>3/4 CtW on 1603</u>
MAIN TO PROP. LINE					<u>Tied over 133'</u>	<u>3/4 Plastic on 1601</u>
PROP. LINE TO BLDG.					<u>split Services</u>	

ENTERS: 1601 Fair Field Dr BRANCHED INTO: 1603 Fair Field Dr

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 18' E of Cof Hawthorne Dr.

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL


MAIN-SIZE 2" C.I. BARE STEEL 1" COATED STEEL PLASTIC ✓ YEAR INSTALLED 1993

DEPTH: 4 Ft. 0 In. LOCATION 20' S of Cof Fair Field Dr.

"A" P/S READING Plastic TOTAL ANODES 1# 17# L.R. #

REMARKS: Tied Tracer Wire OFF At Tee. Found Insulating Dresser & Bonded.

Bare Main Replacement
Program



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser 1601 Riser 1603
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY

1.1 3/4 CtW
PLASTIC