

LOCATION 1612 Fairfield drCITY GasconiaBETWEEN Dartmouth drSTREET & Dartmouth dr

STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>3'</u>	<u>6-25-99</u>	<u>trail over 140' 3/4 C/W Ser.</u>	
MAIN TO PROP. LINE					<u>to Ext 2" P. main</u>	
PROP. LINE TO BLDG.						

ENTERS: 1612BRANCHED INTO: —TAP SIZE: 1/2

PRESSURE

P.S.I.

INCHES W.C.

LOCATION 18' E. of C of  
Fairfield drPRESSURE TEST: @ 100 psi For 4 Hrs. By GPMAIN-SIZE 2" C.I. — BARE STEEL — COATED STEEL — PLASTIC ✓ YEAR INSTALLED 1992DEPTH: 3 Ft. 0 In. LOCATION"A" P/S READING .600TOTAL ANODES 1# 1 17# —L.R. # —REMARKS: test wire off at Main. Bonded dresser

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>SR</u>	<u>.900</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY