

LOCATION

1622 Fairfield Dr.

CITY

Easton, N.J.

BETWEEN

Dartmouth

STREET &

Dartmouth

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	3'	7-6-94	Tied over	107' of ext
MAIN TO PROP. LINE						3/4 4w Service
PROP. LINE TO BLDG.					TO ext 2" P. main	

ENTERS:

1622

BRANCHED INTO:

0

TAP SIZE:

1/2

PRESSURE

60

P.S.I.

INCHES W.C.

LOCATION

PRESSURE TEST:

@ 100 psi

For

1 1/4 Hrs.

By

EP

MAIN-SIZE

2"

C.I.

BARE STEEL

COATED STEEL

PLASTIC

YEAR INSTALLED

1999

DEPTH:

3

Ft.

6

In.

LOCATION

"A" P/S READING

P

TOTAL ANODES


1

17

L.R. #

REMARKS:

Timer wire tied off at drain



Test Station

ENG. DEPT. USE ONLY

Reading & Location

Lead

Volts

P/S Pipeline Lead - Red
New ServiceR/S
R/Sar

1.2

P/S Pipeline Lead - White
Existing Main

E