

LOCATION 1703 Fairfield DrCITY GastoniaBETWEEN Fairfield DrSTREET & Hawthorn


STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	32'	7-2-94	Tied over	78' Existing
MAIN TO PROP. LINE					3/4' P. To	Existing 2"
PROP. LINE TO BLDG.					Plastic Main	

ENTERS: 1703BRANCHED INTO: 0TAP SIZE: 1/2PRESSURE 60 P.S.I. _____ INCHES W.C.LOCATION 177' N of c of
FairfieldPRESSURE TEST: @ 100 psi For 1/4 Hrs. By BCMAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1993DEPTH: 3 Ft. _____ In. LOCATION 16' W of C of Fairfield"A" P/S READING PlasticTOTAL ANODES 1* — 17* —

L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY