

LOCATION 1704 Fairfield Dr

CITY Gastonia

BETWEEN Fairfield Dr

STREET &amp; Hawthorne

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	5'	7-2-94	Tied over	110' Existing
MAIN TO PROP. LINE					3/4" clw to	existing 2"
PROP. LINE TO BLDG.					Plastic Main	

ENTERS: 1704'

BRANCHED INTO: 0

TAP SIZE: 1/2

PRESSURE

60

P.S.I.

INCHES W.C.

LOCATION

175' N of C

of Fairfield

PRESSURE TEST: @ 100 psi

For 1/4 Hrs.

By BC

MAIN-SIZE 2

C.I.

BARE STEEL

COATED STEEL

PLASTIC ☒

YEAR INSTALLED 1993

DEPTH: 3

Ft.

In.


LOCATION 16' W of C of Fairfield Dr

"A" P/S READING plastic

TOTAL ANODES 1\* 1 17\*

L.R. #

REMARKS: Tied wire off at Main



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	1.1
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY