

LOCATION 1806 FAir Field Dr

CITY GASTONIA

BETWEEN Picadilly Circle

STREET &amp; 1804 FAir Field Dr.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	5'	6-18-94	Tied over 80'	Original
MAIN TO PROP. LINE					Existing 3/4	Installation
PROP. LINE TO BLDG.					Plastic	2-3-86

ENTERS: 1806

BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 40' N of C of FAir Field Dr.

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL


MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 3 Ft. 0 In. LOCATION 19' E of C of FAir Field Dr.

"A" P/S READING PLASTIC TOTAL ANODES 1\* 17\* L.R. #

REMARKS:

Bare Main Replacement  
Program



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser Plastic
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY