

LOCATION 1810 Fairfield Dr CITY Houston
 BETWEEN Piccadilly Cir STREET & Fairfield Dr STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Steel</u>	<u>101</u>		<u>7-2-94</u>	
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>84</u>			<u>7-2-94</u>
PROP. LINE TO BLDG.	<u>3/4</u>	<u>"</u>	<u>6</u>			
	<u>3/4</u>	<u>"</u>	<u>78</u>			

ENTERS: 1810 BRANCHED INTO:
 TAP SIZE: 1/2 PRESSURE _____ P.S.I. _____ INCHES W.C. LOCATION N side of house

PRESSURE TEST: @ 100 psi For 44 Hrs. By Bennett

MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1993


DEPTH: 2 Ft. 6 In. LOCATION 19' Edge of lot

"A" P/S READING _____ TOTAL ANODES 1* _____ 17* _____ L.R. # _____

REMARKS:

Bare Main Replacement
Program

Retired Service Purged
With Air And
Capped With M.S.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY