

LOCATION

2401 Fairgreen DR.

CITY

CASTONIA

BETWEEN

Farmbrook DR

STREET &

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	132'	8-20-96		
MAIN TO PROP. LINE	3/4"	P	7'			
PROP. LINE TO BLDG.	3/4"	P	125'			

ENTERS: 2401

BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 62' W. of center of Fairgreen Dr.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Hunkeler

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1996

DEPTH: 3 FT. 0 IN. LOCATION 13' N. of center of Farmbrook Dr.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 452093

REMARKS:



Test Station

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY