

LOCATION 2505 Fairgreen Dr. CITY Bastonia

BETWEEN Farmbrook Dr. STREET & Rosehaven Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>84'</u>	<u>3-11-97</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>4'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>80'</u>			

ENTERS 2505 BRANCHED INTO

TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W C LOCATION 150' S. of center of Farmbrook Dr.


PRESSURE TEST: @ 160 PSI FOR 44 HRS BY S. HOFFSTADT

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1996

DEPTH: 3 FT 0 IN LOCATION 14' W. at center of Fairgreen Dr.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 132109

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY