

LOCATION 2510 Fairgreen DR CITY CASSTONIA
BETWEEN Farmbrook DR, STREET & Rosehaven DR. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>115'</u>	<u>10-5-96</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>30'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>85'</u>			

ENTERS: 2510 BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 260' S. of center
of Farmbrook Dr.

PRESSURE TEST: @ 100 psi For 4 Hrs. By S. Huppert
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1996
DEPTH: 3 Ft. 0 In. LOCATION 13' W. of center of Fairgreen DR.

"A" P/S READING P TOTAL ANODES 1* 0 17* 0 L.R. # 553250

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY