

LOCATION 2514 Fairgreen DR. CITY Gastonia

BETWEEN Rosehauer DR STREET & Farmbrook DR STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	110'	8-20-96		
MAIN TO PROP. LINE	3/4"	P	30'			
PROP. LINE TO BLDG.	3/4"	P	80'			

ENTERS: 2514 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION 128' N. of center of

Rosehauer DR


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Huffstuth

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1996

DEPTH: 3 FT. 0 IN. LOCATION 12' W. of center of Fairgreen DR

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 452104

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY