

LOCATION 2500 Fairgreen DR CITY CASTONIA
BETWEEN Rosehaven DR STREET & Berky Rd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	118'	5-27-97		
MAIN TO PROP. LINE	3/4"	P	35'			
PROP. LINE TO BLDG.	3/4"	P	83'			

ENTERS: 2500 BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION 69' SE. of center of


Rosehaven DR
PRESSURE TEST: @ 100 PSI FOR 44 HRS BY S. Hultsch

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1996

DEPTH: 3 FT. 0 IN. LOCATION 12' SW. of center of Fairgreen DR

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 336656

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY