

LOCATION 2605 Fairgreen Dr CITY GASTONIA

BETWEEN Roseham Dr STREET & Becky Rd STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	68'	8-19-96		
MAIN TO PROP. LINE	3/4"	P	10'			
PROP. LINE TO BLDG.	3/4"	P	58'			

ENTERS: 2605 BRANCHED INTO:

TAP SIZE: 3/4 PRESSURE 60 PSI INCHES W.C. LOCATION 122' S. of center d

Roseham Dr.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Hufstetler

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1996

DEPTH: 3 FT. 0 IN. LOCATION 15' W. of center d Fairgreen Dr

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 452103

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY