

LOCATION 2609 FARGREEN DR CITY CASTLETON

BETWEEN Beatty Rd. STREET & Rosehman DR STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	71'	8-16-96		
MAIN TO PROP. LINE	3/4"	P	5'			
PROP. LINE TO BLDG.	3/4"	P	66'			

ENTERS: 2609 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI INCHES W.C. LOCATION 311' S. of center of

Rosehman Dr.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. HARTSHORN

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1996

DEPTH: 3 FT. 0 IN. LOCATION 15' W. of center of FARGREEN DR.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 432190

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY