

COPY

LOCATION 2547 Fairview Dr. CITY San Antonio

BETWEEN Hewon St. STREET & Lewallen St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>Plastic</u>	<u>175'</u>	<u>4-5-02</u>	<u>175' of Existing 3/4"</u>	
MAIN TO PROP LINE	<u>5/8"</u>	<u>Plastic</u>	<u>17'</u>		<u>ctw pipe</u>	
PROP LINE TO BLDG	<u>5/8"</u>	<u>Plastic</u>	<u>158'</u>			

ENTERS 2547 BRANCHED INTO 0

TAP SIZE 3/4 PRESSURE 600 PSI _____ INCHES W.C. LOCATION 510' E of C of Hewon St.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY RL

MAIN SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 2002

DEPTH 3 FT 6 IN LOCATION 13' S of C of Fairview Dr.

"A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 LR # _____

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	S	Riser Plastic
P/S Pipeline Lead White Existing Main	E	