


LOCATION 2773 Fairview Dr. CITY EASTONIA
 BETWEEN Jenkins Dairy Rd. STREET & Dallas Bessemer City Rd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>Plastic</u>	<u>200'</u>	<u>6-7-00</u>	<u>100'</u>	<u>3/4 CFW Pipe</u>
MAIN TO PROP LINE	<u>3/4</u>	<u>Plastic</u>	<u>50'</u>			<u>system Enhancement</u>
PROP LINE TO BLDG	<u>3/4</u>	<u>Plastic</u>	<u>150'</u>			

 ENTERS 2773 BRANCHED INTO 0
 TAP SIZE 3/4 PRESSURE 600 PSI _____ INCHES W.C. LOCATION 355' W of Cap Jenkins Dairy Rd.
 PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY RL
 MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 2000
 DEPTH 3 FT 6 IN LOCATION 28' N of Cap Fairview Dr.
 "A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 LR # _____

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser Plastic</u>
P/S Pipeline Lead White Existing Main	<u>E</u>	