

LOCATION 2787 Fairview Dr. CITY DARTONIA  
 BETWEEN JENKINS DAIRY Rd. STREET & BELLINGER DALLAS Rd.

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED
MAIN TO BLDG	<u>3/4</u>	<u>Plastic</u>	<u>180'</u>	<u>6-8-00</u>	<u>150' Exist</u>
MAIN TO PROP LINE	<u>3/4</u>	<u>Plastic</u>	<u>50'</u>		<u>C&amp;W Pipe</u>
PROP LINE TO BLDG	<u>3/4</u>	<u>Plastic</u>	<u>130'</u>		

ENTERS 2787 BRANCHED INTO 0  
 TAP SIZE 3/4 PRESSURE 100 PSI INCHES W C LOCATION 55' W of  
DAIRY

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY RL

MAIN-SIZE 2 1/4 C I BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED

DEPTH 3 FT 6 IN LOCATION 22' W of C of Fairview Dr.

"A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 I R #

REMARKS

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>

