


LOCATION	3421 Fairview DR			CITY	Gastonia	
BETWEEN	Steele DR.			STREET &	Dallas - Brown City Rd.	
	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4"	P	216'	4-19-00		
MAIN TO PROP LINE	3/4"	P	58'			
PROP LINE TO BLDG	3/4"	P	166'			
ENTERS	3421			BRANCHED INTO		
TAP SIZE	3/4"	PRESSURE	60 PSI	INCHES W C	LOCATION 36' N. of center of Steele DR.	
PRESSURE TEST @	100 PSI	FOR	44 HRS	BY	S.H.	
MAIN-SIZE	2"	C I	BARE STEEL	COATED STEEL	PLASTIC	YEAR INSTALLED
DEPTH	3 FT	0 IN	LOCATION 20' N. of center of Fairview DR			
"A" P/S READING	P			TOTAL ANODES 1#	0	17# 0
LR #	532074					

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	