

LOCATION 3525 Fairview LI CITY Stastonia

BETWEEN Stiles STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>22.6</u>			
MAIN TO PROP LINE	<u>3/4</u>	<u>P</u>	<u>60</u>	<u>2-3-97</u>		
PROP LINE TO BLDG	<u>3/4</u>	<u>P</u>	<u>166'</u>			

ENTERS 352.5 BRANCHED INTO

TAP SIZE 3/8 PRESSURE 60 PSI INCHES W C LOCATION


PRESSURE TEST 100 PSI FOR 1 1/4 HRS BY EP

MAIN SIZE 2" C I BARE STEEL COATED STEEL ☒ PLASTIC YEAR INSTALLED 1975

DEPTH 2 FT 6 IN LOCATION

"A" P/S READING 4.3 TOTAL ANODES 1# 17# LR #

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	<u>S</u>	<u>0.645V</u>
P/S Pipeline Lead White Existing Main	<u>E</u>	