

LOCATION 118 Fairway Ln CITY GASTONIA
BETWEEN FRANKLIN Blvd. STREET & West Club Circle STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>96'</u>	<u>12-15-97</u>	<u>Retired 3/4" CW</u>	
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>36'</u>		<u>Purged with Air + capped</u>	
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>60'</u>		<u>original Inst.</u>	<u>10-29-66</u>

ENTERS: Same BRANCHED INTO:
TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 160' south of West Club


18' west of Fairway Ln.
PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY BB

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1997

DEPTH: 3 FT. 6 IN. LOCATION 18' west of Fairway Ln.

"A" P/S READING P. TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS: Retired + Renewed Service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P. Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY