

LOCATION 121 Fairway Ln CITY Gastonia
BETWEEN West Club Circle STREET & FRANKLIN Blvd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	31'	12-16-97	Retired 3/4" C+W	
MAIN TO PROP. LINE	3/4	P	1'		Purged with Air + capped	
PROP LINE TO BLDG.	3/4	P	30'		Orig. Inst.	10-2-72

ENTERS: Same

BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 72' west of Fairway Ln +
13' South of West Club Cir.


PRESSURE TEST: @ 100# PSI FOR 1/4 HRS BY BB

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT. 6 IN LOCATION 13' South of West Club Cir.

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS: Retired + Renewed Service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>P</u>	<u>P. Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY