

LOCATION 206 Fairway Dr CITY Gastonia
BETWEEN Shepard STREET & Cedar STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>117'</u>	<u>3-17-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>17'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>100'</u>			

ENTERS: 206 BRANCHED INTO: 0
TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION S. Side of 206

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By BC
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1994
DEPTH: 3 Ft. _____ In. LOCATION 13' W of C of Fairway

"A" P/S READING plastic TOTAL ANODES 1* - 17* - L.R. # 93189

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY