

LOCATION 213 FAIRWAY Dr CITY GASTONIA  
BETWEEN Shepherd STREET & Cedar St. STR

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>110'</u>	<u>4-12-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>34'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>76'</u>			

ENTERS: 213 BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 245' N of C of Cedar St.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL

MAIN-SIZE 2" C.I.      BARE STEEL      COATED STEEL      PLASTIC ✓ YEAR INSTALLED 1994

DEPTH: 3 Ft. 0 In. LOCATION 13' W of C of FAIRWAY Dr.

"A" P/S READING P TOTAL ANODES 1#      17#      L.R. #     

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY