


LOCATION 310 Fairway DrCITY GastoniaBETWEEN HollifieldSTREET & Cedar

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	314	P	70'	3-17-94		
MAIN TO PROP. LINE	"	"	12'			
PROP. LINE TO BLDG.	"	"	58'			

ENTERS: 310BRANCHED INTO: 0TAP SIZE: 1/2 PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION S. Side of 310PRESSURE TEST: @ 100 psi For 1/4 Hrs. By BCMAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1994DEPTH: 3 Ft. In. LOCATION"A" P/S READING plastic TOTAL ANODES 1\* - 17\* - L.R. # 903/89

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY