

LOCATION 683 falcons nest ct.CITY GastoniaBETWEEN Hawks RidgeSTREET & OSPREY

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>69'</u>	<u>11-11-99</u>		
MAIN TO PROP LINE	<u>1"</u>	<u>1"</u>	<u>2'</u>			
PROP LINE TO BLDG	<u>1"</u>	<u>1"</u>	<u>62'</u>			

ENTERS 683BRANCHED INTO —TAP SIZE 1/2

PRESSURE

PSI

INCHES W C

LOCATION 19' S. of CofPRESSURE TEST @ 100 PSIFOR 1/4 HRSBY SPfalcons nestMAIN-SIZE 2

C I

BARE STEEL

COATED STEEL

PLASTIC ☒YEAR INSTALLED 1997DEPTH 3 FT 0 IN

LOCATION


A P/S READING P

TOTAL ANODES 1#

17#

LR #

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>OR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	