

LOCATION 707 N- Falls St. CITY GASTONIA
BETWEEN Bradley STREET & Harrison Ave. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>75'</u>	<u>11-9-95</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>30'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>45'</u>			

ENTERS: 707 BRANCHED INTO: 0
TAP SIZE: 3/8 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 104' S of C of Harrison Ave.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL

MAIN-SIZE 2" C.I. _____ BARE STEEL ☒ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED 1954

DEPTH: 2 Ft. 0 In. LOCATION 10' E of C of N- Falls St.

"A" P/S READING 60 TOTAL ANODES 1# _____ 17# 1 L.R. # 574511

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser PLASTIC
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY