

LOCATION 707 N. Falls St. CITY CAST.

BETWEEN W. Harrison Ave STREET & W. Bradley Ave. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	48'	1/2 over 11/23/96		
MAIN TO PROP. LINE	1"	"	8'			
PROP. LINE TO BLDG.	1"	"	50'			

ENTERS: Same BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION 114' South from @ of N.

Harrison Ave.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY TM


MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC P YEAR INSTALLED 1996

DEPTH: 3 FT. 0 IN. LOCATION West Side of N. Falls St.

"A" P/S READING P TOTAL ANODES 1# 17# L.R. #

REMARKS: 7/2 over 48' 6" Ex 3/4" Ser to 707

with 10' of 3/4" Plastic Pipe



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY