

LOCATION 709 N. Falls St. CITY CAS.

BETWEEN W. Harrison St. STREET & W. Bradley St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>34'</u>			<u>9-9-96</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>29'</u>			

ENTERS: Same BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 24' south from @ of

W. Harrison Ave


PRESSURE TEST: @ 100 PSI FOR 44 HRS. BY ml

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 96

DEPTH: 3 FT. 0 IN. LOCATION West Side of N. Falls St.

"A" P/S READING P TOTAL ANODES 1# 17# L.R. # _____

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	<u>S</u>		
	P/S Pipeline Lead - White Existing Main	<u>E</u>		