

LOCATION 713 N. Falls St. CITY Coast.

BETWEEN Harrison St. STREET & W. Bradley St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>8'</u>			<u>9-9-96</u>
MAIN TO PROP. LINE	<u>1"</u>	<u>1"</u>	<u>8'</u>			
PROP. LINE TO BLDG.	<u>1"</u>	<u>1"</u>	<u>8'</u>			

ENTERS: Same BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION 47' South from @ of Allison St.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY TM

MAIN SIZE 3/4" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 96

DEPTH: 1 FT. 6 IN. LOCATION South side of 713 N. Falls St.

"A" P/S READING P TOTAL ANODES 1# 17# L.R. #

REMARKS:

	Test Station		
	Reading & Location	Lead	Volts
	P/S Pipeline Lead - Red New Service	<u>S</u>	
	P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY