

LOCATION 714 N. Falls St. CITY Coast.
BETWEEN W. Harrison St. STREET & Allison St. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>55'</u>			<u>9-10-96</u>
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>29'</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>26'</u>			

ENTERS: Same BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 56' East from @ of N. Falls St.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY my
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 96
DEPTH: 3 FT. 0 IN. LOCATION South Side of W. Harrison Ave.

"A" P/S READING P TOTAL ANODES 1# 17# L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY