

LOCATION 718 N. Falls St. CITY Cast.
BETWEEN Allison St. STREET & W. Davidson Ave STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>83'</u>		<u>12-10-96</u>	
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>31'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>52'</u>			

ENTERS: Same BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 91' from @ of Allison St.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY mmj
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 96
DEPTH: 3 FT. 0 IN. LOCATION West side of N. Falls St.

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY