

LOCATION 725 N. Falls St. CITY CASTONIA

BETWEEN W. Davidson St. STREET & Allison St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>28'</u>		<u>12-6-96</u>	
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>8'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>20'</u>			

ENTERS: SAME BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION 82' from @ of W. Davidson Ave

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY M

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 96

DEPTH: 3 FT. 0 IN. LOCATION West Side of Falls Ave

"A" P/S READING P TOTAL ANODES 1# — 17# — L.R. # —

REMARKS:

Test Station			ENG. DEPT. USE ONLY
Reading & Location	Lead	Volts	
P/S Pipeline Lead - Red New Service	<u>S</u>		
P/S Pipeline Lead - White Existing Main	<u>E</u>		

