

LOCATION 4413 Farmbrook Dr CITY CASPER, WY

BETWEEN Core Creek Dr. STREET & Derry Down Ln. STREET

|                     | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------|------|--------|-----------|---------|---------|
| MAIN TO BLDG.       | 3/4" | P    | 85'    | 8-2-96    |         |         |
| MAIN TO PROP. LINE  | 3/4" | P    | 10'    |           |         |         |
| PROP. LINE TO BLDG. | 3/4" | P    | 75'    |           |         |         |

ENTERS: 4413 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 40 PSI \_\_\_\_\_ INCHES W.C. LOCATION 382' Sw. of center

of Core Creek Dr


PRESSURE TEST: @ 100 PSI FOR 44 HRS. BY S. Huff 8/26

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1996

DEPTH: 3 FT. 0 IN. LOCATION 13' Nw. of center of Farmbrook Dr

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 403657

REMARKS:



| Test Station                               |      |       |
|--------------------------------------------|------|-------|
| Reading & Location                         | Lead | Volts |
| P/S Pipeline Lead - Red<br>New Service     | S    |       |
| P/S Pipeline Lead - White<br>Existing Main | E    |       |

ENG. DEPT. USE ONLY