

LOCATION 4418 Farmbrook Rd. CITY Gastonia

BETWEEN Derrydown Ln STREET & Cove Creek STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	113'	7-9-96		
MAIN TO PROP. LINE	3/4"	P	38'			
PROP. LINE TO BLDG.	3/4"	P	83'			

ENTERS: 4418 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI INCHES W.C. LOCATION 108' N. of center of

Derrydown Ln.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. HUR

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1996

DEPTH: 3 FT. 0 IN. LOCATION 12' W of center of Farmbrook Rd.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 371980

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	S		
	P/S Pipeline Lead - White Existing Main	E		