

LOCATION 4505 Farmbrook Rd. CITY Castroville

BETWEEN Derrydown Ln. STREET & Dead End STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>91'</u>	<u>4-22-97</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>20'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>71'</u>			

ENTERS. 4505 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 172' S. of center of

Derrydown Ln.

PRESSURE TEST @ 100 PSI FOR 1/4 HRS. BY S. Huffstetler

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1996

DEPTH: 3 FT 0 IN. LOCATION 13' W. of center of Farmbrook Rd.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 241924

REMARKS:




Diagram of test station layout showing Main - White and Service - Red lines with electrodes N, S, E, W, and A.

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY