

LOCATION 1702 Farm Pond Ct. CITY Easton, IA
 BETWEEN Windy Rush LN. STREET & End of Culdesack STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>Plastic</u>	<u>117'</u>	<u>8-10-00</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>Plastic</u>	<u>5'</u>			
PROP LINE TO BLDG	<u>3/4</u>	<u>Plastic</u>	<u>112'</u>			

ENTERS 1700 BRANCHED INTO 1700

TAP SIZE 3/4 3way Tee PRESSURE 60 PSI INCHES WC LOCATION 560' N of Cof Windy Rush LN.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY DL

MAIN-SIZE 3/4 C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1988

DEPTH 2 FT 0 IN LOCATION 5' W of Cof Farm Pond Ct.

"A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 LR #

REMARKS



Test Station		
Reading & Location	Lead	Volt
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>2.58</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>