


LOCATION 1345 Fairmount Trl		CITY GASTONIA	
BETWEEN 9th + 11th		STREET & 11th	
MAIN TO BUDG.	SIZE 3/4"	TYPE 8/10/11	LENGTH 57'
MAIN TO PROP LINE	SIZE 3/4"		LENGTH 10'
PROP LINE TO BUDG.	SIZE 3/4"		LENGTH 47'
ENTERS: 1345		BRANCHED INTO	
TAP SIZE: 3/4"		PRESSURE 60 PSI	INCHES WC
LOCATION N 5th & F1345			
PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY DJ			
MAIN SIZE 2"		CL	COATED STEEL
DEPTH 2 FT		IN	LOCATION N 5th & F1345
YEAR INSTALLED 1993			
TOTAL ANODES 18		LR # 853679	
REMARKS:			



Test Station	
Reading & Location	Lead
P/S Pipe Line Lead - Red	S
New Service	E
P/S Pipe Line Lead - White	
Existing Main	