

LOCATION 5203 Featherstone Ct. CITY Canton, MA
BETWEEN Cramer Woods Dr. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>133'</u>	<u>2-23-01</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>45'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>98'</u>			

ENTERS 5203 BRANCHED INTO
TAP SIZE 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 129' S. of center of Cramer Woods Dr.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S.H.

MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED _____

DEPTH 3 FT 0 IN LOCATION 19' W. of center of Featherstone Ct.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 131129

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	