

LOCATION 5210 FEATHERSTONE CT CITY GASTONIA
BETWEEN OLD TOWN LN STREET & SUMMERELL AVE STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>76'</u>	<u>7-6-01</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>P</u>	<u>12'</u>			
PROP LINE TO BLDG	<u>3/4</u>	<u>P</u>	<u>54'</u>			

ENTERS 5210 BRANCHED INTO 0

TAP SIZE 1/2 PRESSURE 60 PSI _____ INCHES W C LOCATION 333'S OF C OF

CRAMER WOODS DR


PRESSURE TEST @ 100 PSI FOR 4 HRS BY R.R.

MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1999

DEPTH 3 FT 0 IN LOCATION 18' W OF C OF FEATHERSTONE CT

"A" P/S READING plastic TOTAL ANODES 1# 0 17# 0 LR # 0545345

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>plastic</u>
P/S Pipeline Lead White Existing Main	<u>E</u>	<u>Riser</u>