

LOCATION 5314 Featherstone CT CITY Castoria

BETWEEN Cramer Woods Dr STREET & Cost de Site STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>96'</u>			
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>10'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>86'</u>			

ENTERS 5314 BRANCHED INTO

TAP SIZE 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 364' S. of center of Cramer Woods Dr


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S.K.

MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 2000

DEPTH 3 FT 0 IN LOCATION 18' W. of center of Featherstone CT

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 I.R. # 163314

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	