

LOCATION 5218 FEATHERSTONE CT CITY GASTONIA  
BETWEEN CRAMER WOODS DR STREET & DEAD END STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>100'</u>	<u>11-22-00</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>P</u>	<u>17'</u>			
PROP LINE TO BLDG	<u>3/4</u>	<u>P</u>	<u>83'</u>			

ENTERS 5218 BRANCHED INTO 0  
TAP SIZE 1/2 PRESSURE 60 PSI INCHES WC LOCATION 458' S of C of  
CRAMER WOODS DR

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY RJR

MAIN-SIZE 2" C I        BARE STEEL        COATED STEEL        PLASTIC        YEAR INSTALLED 1999

DEPTH 3 FT 0 IN LOCATION 19' W of C of FEATHERSTONE CT

"A" P/S READING PLASTIC TOTAL ANODES 1# 0 17# 0 LR # 1104276

REMARKS

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Riser</u>

