


LOCATION	1267 Fenwick Hall			CITY	Gastonia	
BETWEEN	Plantation Trail		STREET &	STREET		
	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	68'	3-4-95		
MAIN TO PROP. LINE	3/4"	P	5			
PROP. LINE TO BLDG.	3/4"	P	63'			
ENTERS: 1267 BRANCHED INTO:						
TAP SIZE: 1/2	PRESSURE 60 P.S.I.			INCHES W.C.		LOCATION 126' E. of center of Plantation Trail
PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. Huffstutler						
MAIN-SIZE 2"	C.I. BARE STEEL COATED STEEL PLASTIC <input checked="" type="checkbox"/>			YEAR INSTALLED 1994		
DEPTH: 3 Ft. 0 In.	LOCATION 17' S. of center of Fenwick Hall					
"A" P/S READING P	TOTAL ANODES 1# 0 17# 0			L.R. # 43084		

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY