

LOCATION 3904 Ferncliff Dr. CITY Castalia  
BETWEEN Greenhaven Dr. STREET & STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>80'</u>	<u>4-19-95</u>		
MAIN TO PROP. LINE	<u>3/4'</u>	<u>P</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>3/4'</u>	<u>P</u>	<u>75'</u>			

ENTERS: 3904 BRANCHED INTO:  
TAP SIZE: 1/2 PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION 376' N. of center of Green Haven Dr.

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. HUFFSTADT  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1968  
DEPTH: 3 Ft. 0 In. LOCATION 16' E. of center of Ferncliff Dr.

"A" P/S READING 1.2 TOTAL ANODES 1\* 0 17\* 0 L.R. # 18282

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY