

LOCATION 3457 Fieldstone Dr. CITY Gastonia

BETWEEN Rocky Creek STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>Plastic</u>	<u>45'</u>	<u>3-3-00</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>Plastic</u>	<u>3'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>Plastic</u>	<u>42'</u>			

ENTERS 3457 Fieldstone BRANCHED INTO 3464 Fieldstone

TAP SIZE 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION 553' N. of center of Rocky Creek to.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY CL

MAIN SIZE 3/4" PLASTIC C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1999

DEPTH FT. IN IN LOCATION 75' From Right Corner of 3457 to 2x 3/4 Tee. 2000

A P/S READING N/A TOTAL ANODES I# 17# LR #

REMARKS



Test Station		
Reading & Location	Lead	Valis
P/S Pipeline Lead Red New Service	S	Riser
P/S Pipeline Lead White Existing Main	E	Plastic