

LOCATION 3465 Fieldstone Dr CITY Gastonia

BETWEEN Rock Creek Ct STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4"	P	101'	7-5-01		
MAIN TO PROP LINE	3/4"	P	5'			
PROP LINE TO BLDG	3/4"	P	96'			

ENTERS 3465 BRANCHED INTO

TAP SIZE 3/4" PRESSURE 60 PSI INCHES W C LOCATION 440' NE of center of Rock Creek Ct


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY SOA

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED Zero

DEPTH 3 FT 0 IN LOCATION 34' NW of center of Fieldstone Dr

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 545311

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	