

LOCATION 3481 Fieldstone Dr. CITY Gastonia
BETWEEN Rock Creek Ct. STREET & Misty Ridge Ct. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	5/8"	P	116'	10-7-62		
MAIN TO PROP LINE	5/8"	P	42'	"		
PROP LINE TO BLDG	5/8"	P	74'	"		

ENTERS 3481 BRANCHED INTO 0

TAP SIZE 3/4" PRESSURE 160 PSI _____ INCHES WC LOCATION 287' north of


center of Rock Creek Ct.
PRESSURE TEST @ 160 PSI FOR 1/4 HRS BY D. Woody

MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1999

DEPTH 3' FT 0" IN LOCATION 20' East of center of Fieldstone Dr.

"A" P/S READING N/A TOTAL ANODES 1# 0 17# 0 LR # C0096533

REMARKS New Plastic Service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	E	<u>Service</u>